



Note:

- This drawing is subject to ESB design approval and should not be used for construction.
- This drawing is to be read in conjunction with relevant drawings, specifications and reports.
- Dimensions are in millimeters, unless noted otherwise.
- Drawings are not to be scaled use figured dimensions only.
- The compaction of backfill material around the cables shall be carried out by hand.
- The Contractor shall provide test certificates confirming that the thermal resistivity of the thermal sand is maximum 1.K.m/W.

ALL REINSTATEMENT WORKS ARE TO BE IN ACCORDANCE WITH LOCAL AREA ENGINEERS REQUIREMENTS AND GUIDELINES FOR MANAGING OPENINGS IN PUBLIC ROADS



Head Office
 Beenreigh,
 Abbeydorney,
 Tralee, Co. Kerry
 Ireland
 Tel: 00353 66 7135710

CLIENT



PROJECT

Clondardis 110kV Substation

PROJECT NUMBER
 05-916

SHEET NUMBER
 05916-DR-216

SHEET TITLE

Joint Bay Arrangement

DRAWING STATUS
 For SID Planning

ISSUE/REVISION

NO.	DATE	DESCRIPTION
P00	21.12.22	For SID Planning
I/R	DATE	DESCRIPTION